



STATE OF DELAWARE  
OFFICE OF THE STATE FIRE MARSHAL

GROVER P. INGLE  
STATE FIRE MARSHAL

DOVER OFFICE  
HEADQUARTERS

August 31, 2022

**RE: NFPA 70, *National Electric Code*, Tentative Interim Amendment (TIA) 20-19**

To Whom It May Concern:

Effective September 1, 2022, the attached Tentative Interim Amendment (TIA) from the National Fire Protection Association (NFPA) is permitted to be utilized as part of the 2020 edition of NFPA 70, *National Electric Code*.

Please contact me if you have any questions at [John.Rudd@delaware.gov](mailto:John.Rudd@delaware.gov) or at 302-739-4394.

Sincerely,

John W. Rudd, CFPS, CFI-II, CFPE  
Chief of Technical Services Division



Tentative Interim Amendment

## NFPA<sup>®</sup> 70<sup>®</sup>

### *National Electrical Code<sup>®</sup>*

#### 2020 Edition

**Reference:** 210.8(F) and Exception No. 2(new)

**TIA 20-19**

(SC 22-8-16 / TIA Log #1653)

Pursuant to Section 5 of the NFPA *Regulations Governing the Development of NFPA Standards*, the National Fire Protection Association has issued the following Tentative Interim Amendment to NFPA 70<sup>®</sup>, *National Electrical Code<sup>®</sup>*, 2020 edition. The TIA was processed by the NEC Code-Making Panel 2, and the NEC Correlating Committee, and was issued by the Standards Council on August 12, 2022, with an effective date of September 1, 2022.

1. *Revise paragraph 210.8(F) to read as follows:*

**210.8(F) Outdoor Outlets.**

All outdoor outlets for dwellings, other than those covered in 210.8(A)(3), Exception to (3), that are supplied by single-phase branch circuits rated 150 volts to ground or less, 50 amperes or less, shall have ground-fault circuit-interrupter protection for personnel. ~~This requirement shall become effective on January 1, 2023, for mini split type heating/ventilating/air conditioning (HVAC) equipment and other HVAC units employing power conversion equipment as a means to control compressor speed.~~

~~Informational Note: Power conversion equipment is the term used to describe the components used in HVAC equipment that is commonly referred to as a variable speed drive. The use of power conversion equipment to control compressor speed differs from multistage compressor speed control.~~

~~Exception No. 1: Ground-fault circuit-interrupter protection shall not be required on lighting outlets other than those covered in 210.8(C).~~

~~Exception No. 2: Ground-fault circuit-interrupter protection shall not be required for listed HVAC equipment. This exception shall expire September 1, 2026.~~

**Issue Date:** August 12, 2022

**Effective Date:** September 1, 2022

(Note: For further information on NFPA Codes and Standards, please see [www.nfpa.org/docinfo](http://www.nfpa.org/docinfo))

Copyright © 2022 All Rights Reserved

NATIONAL FIRE PROTECTION ASSOCIATION